



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

证书编号/No.: 2021122315114304

认证委托人名称: Hauber Elektronik GmbH

认证委托人地址: Fabrikstr.6, 72622 Nuertingen

生产者名称: Hauber Elektronik GmbH

生产者地址: Fabrikstr.6, 72622 Nuertingen

生产企业名称: Hauber Elektronik GmbH (L046576)

生产企业地址: Fabrikstr.6, 72622 Nuertingen

认证依据标准: GB 3836.1-2010, GB 3836.2-2010, GB 12476.1-2013,
GB 12476.5-2013

产品名称: 振动传感器

系列/型号/规格: HE100.01, HE101.01, HE102.01, HE103.01; 电气参数见附件;
防爆标志: Ex d IIC T4 Gb, Ex tD A21 IP6X T120°C

上述产品符合《强制性产品认证实施规则 防爆电气》(CNCA-C23-01: 2019)的要求, 特发此证。

发证日期: 2021年05月18日

有效期至: 2026年05月17日

此证书的有效性以定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 或产品客服电话 400-176-1888 查询。



Handwritten signature



方圆标志认证集团

地址: 北京市海淀区增光路33号(100048)
<http://www.cqm.com.cn>

A 0048307



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. 2021122315114304

NAME AND ADDRESS OF THE APPLICANT

Hauber Elektronik GmbH
Fabrikstr.6, 72622 Nuertingen

NAME AND ADDRESS OF THE MANUFACTURER

Hauber Elektronik GmbH
Fabrikstr.6, 72622 Nuertingen

NAME AND ADDRESS OF THE FACTORY

Hauber Elektronik GmbH
Fabrikstr.6, 72622 Nuertingen

CERTIFICATION STANDARDS

GB 3836.1-2010,GB 3836.2-2010,GB 12476.1-2013,GB 12476.5-2013

NAME, MODEL AND SPECIFICATION

Vibration Sensor

HE100.01, HE101.01, HE102.01, HE103.01; Electrical parameters, refer to attachment for details;

Ex marking: Ex d IIC T4 Gb, Ex tD A21 IP6X T120°C

THIS CERTIFICATE IS ISSUED AS VERIFICATION THAT THE PRODUCT(S) MENTIONED ABOVE HAS MET THE REQUIREMENTS OF IMPLEMENTATION RULES FOR CHINA COMPULSORY CERTIFICATION (REF NO. CNCA-C23-01: 2019)

INITIAL DATE: 2021-05-18

DATE OF EXPIRY: :2026-05-17

VALIDITY OF THIS CERTIFICATE IS SUBJECT TO POSITIVE RESULT OF THE REGULAR FOLLOW UP INSPECTION BY THE ISSUING CERTIFICATION BODY UNTIL THE EXPIRY DATE.

THE STATUS AND AUTHENTICITY OF THIS CERTIFICATE MAY BE VERIFIED BY VISITING THE OFFICIAL CNCA WEBSITE: WWW.CNCA.GOV.CN OR BY CONTACTING SERVICE TEL OF CQM: 400-176-1888



Handwritten signature



方圆标志认证集团

ADDRESS: No. 33 Zengguang Road, Haidian District Beijing P.R. China (100048)

<http://www.cqm.com.cn>

A 0048308



中国国家强制性产品认证证书

CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

附 录

第 1 页 共 1 页

证书编号: 2021122315114304

主证纸号: A 0048307

型号: HE100.01, HE101.01, HE102.01, HE103.01

防爆标志: Ex d IIC T4 Gb , Ex tD A21 IP6X T120°C

电气参数:

最大输入电压: 10 V-30 V

HE100.01, HE102.01, HE103.01

最大输入电流: 4mA -25mA

HE101.01

最大输入电流: 8mA -50mA

Ex 设备的特殊使用条件或 Ex 元件的限定使用条件:

- 1) 环境温度范围为-40°C ~ +60°C;
- 2) 通过安装实现集成电位均衡。
- 3) 必须遵守操作说明。

注: 此附录与证书同时使用时有效。



Handwritten signature



方圆标志认证集团

<http://www.cqm.com.cn>

A 0048309